

CERTIFICATE

It is hereby confirmed that the
VAV system CET Solution
for laboratories and clean rooms
of the manufacturer
Siemens Switzerland Ltd

consisting of

- electronic controller DXR2.E17C-103
- venturi air valves: SVV-E108CMNHHE-CL00
SVV-E110CMNHHE-CL00
SVV-E112CMNHHE-CL00
SVV-E114CMNHHE-CL00
- electric actuator GAP191.1E
- differential pressure sensor DXA.S04P1
 - wire sensor HLV20.1
- air velocity sensor QVE3001

was tested according to

EN 14175 part 6

at a pressure range of 150 – 750 Pa.

The details and data of the complete test procedure
are content of the type test reports


**FCS/EN/49/T6/2018, FCS/EN/50/T6/2018, FCS/EN/51/T6/2018 and
FCS/EN/52/T6/2018**

which are given to the manufacturer on


24th May 2018

Tintschl BioEnergie und Strömungstechnik AG
Goerdelerstr. 21
91058 Erlangen
Germany

Controlled by:


Dipl.-Ing. Bernd Schubert

Tested by:


Dipl.-Ing. Zheni Uzunova



Tintschl BioEnergie und Strömungstechnik AG

Erlangen, 24/05/2018