

# » WRF06 AO2V | DI4 RS485 Modbus


Room sensor / room controller w/o operating elements

## Datasheet

Subject to technical alteration  
Issue date: 01.09.2020 · A110

Fits all 55x55 switch ranges

Available in  
 • pure white brilliant  
 • pure white matt  
 • aluminium  
 • anthracite



## » APPLICATION

The flush-mounted room sensor, type DI4 with 4 digital inputs is used for temperature detection in individual room control. Type AO2V can be used to control continuous 2-point controllers or 6-way valves for heating or cooling. The removable connection terminal enables pre-wiring.

## » TYPES AVAILABLE

WRF06 AO2V / DI4 RS485 Modbus

- Room sensor temperature, optional with humidity – DI4 RS485 Modbus  
WRF06 DI4 (*4 digital inputs*)
- Room controller temperature, optional with humidity – AO2V RS485 Modbus  
WRF06 AO2V (*2x 0..10 V | heating / cooling*)

## » TYPE OVERVIEW - FUNCTIONALITY

	Digital Inputs	Internal Controller	0..10 V Heating	0..10 V Cooling	Relay Heating	Relay Cooling	Triac Heating	Triac Cooling	6WV Heating&Cooling
DI4	4								
AO2V	2	•	•	•					•

## » PRODUCT TESTING AND CERTIFICATION



Declaration of conformity

The declaration of conformity of the products can be found on our website <https://www.thermokon.de/>.

## » SECURITY ADVICE – CAUTION



The installation and assembly of electrical equipment should only be performed by authorized personnel.

The product should only be used for the intended application. Unauthorised modifications are prohibited! The product must not be used in relation with any equipment that in case of a failure may threaten, directly or indirectly, human health or life or result in danger to human beings, animals or assets. Ensure all power is disconnected before installing. Do not connect to live/operating equipment.

Please comply with

- Local laws, health & safety regulations, technical standards and regulations
- Condition of the device at the time of installation, to ensure safe installation
- This data sheet and installation manual

## » NOTES ON DISPOSAL



As a component of a large-scale fixed installation, Thermokon products are intended to be used permanently as part of a building or a structure at a pre-defined and dedicated location, hence the Waste Electrical and Electronic Act (WEEE) is not applicable. However, most of the products may contain valuable materials that should be recycled and not disposed of as domestic waste. Please note the relevant regulations for local disposal.

## » REMARKS TO ROOM SENSORS

### Location and Accuracy of Room Sensors

The room sensor should be mounted in a suitable location for measuring accurate room temperature. The accuracy of the temperature measurement also depends directly on the temperature dynamics of the wall. It is important, that the back plate is completely flush to the wall so that the circulation of air occurs through the vents in the cover. Otherwise, deviations in temperature measurement will occur due to uncontrolled air circulation. Also the temperature sensor should not be covered by furniture or similar devices. Mounting next to doors (due to draught) or windows (due to colder outside wall) should be avoided.

The temperature dynamics of the wall will influence the temperature measurement. Various wall types (brick, concrete, dividing and hollow brickwork) all have different behaviours with regards to thermal variations.

### Surface and Flush Mounting

The temperature dynamics of the wall influence the measurement result of the sensor. Various wall types (brick, concrete, dividing and hollow brickwork) have different behaviours with regard to thermal variations. A solid concrete wall responds to thermal fluctuations within a room in a much slower way than a light-weight structure wall. Room temperature sensors installed in flush boxes have a longer response time to thermal variations. In extreme cases they detect the radiant heat of the wall even if the air temperature in the room is lower for example. The quicker the dynamics of the wall (temperature acceptance of the wall) or the longer the selected inquiry interval of the temperature sensor is the smaller the deviations limited in time are.

## » BUILD-UP OF SELF-HEATING BY ELECTRICAL DISSIPATIVE POWER

Temperature sensors with electronic components always have a dissipative power, which affects the temperature measurement of the ambient air. The dissipation in active temperature sensors shows a linear increase with rising operating voltage. This dissipative power has to be considered when measuring temperature. In case of a fixed operating voltage ( $\pm 0,2$  V) this is normally done by adding or reducing a constant offset value. As Thermokon transducers work with a variable operating voltage, only one operating voltage can be taken into consideration, for reasons of production engineering. Transducers 0..10 V / 4..20 mA have a standard setting at an operating voltage of 24 V =. That means, that at this voltage, the expected measuring error of the output signal will be the least. For other operating voltages, the offset error will be increased by a changing power loss of the sensor electronics. If a re-calibration should become necessary later directly on the sensor, this can be done by means of a trimming potentiometer on the sensor board.

**Remark: Occurring draft leads to a better carrying-off of dissipative power at the sensor. Thus temporally limited fluctuations might occur upon temperature measurement.**

## » MOUNTING ADVICES

The device is designed for mounting on a flush-mounted box. The bus cable is connected to the device by a terminal screw. For pre-wiring, the clamping screw can be removed. Due to the space for cabling, the use of deep installation boxes is recommended. The screws of the installation box (maximum torque of the screws 0.8 Nm) can fasten the lower part. The installation must be carried out in representative places for the room temperature, in order to avoid a falsification of the measuring result. Direct sunlight and drafts should be avoided. The end of the installation pipe in the flush-mounted box must be sealed in order to prevent drafts in the pipe. To ensure a smooth and accurate installation, it is essential that the installation boxes used are not jut out from the wall surface. The box must be flush with the wall or slightly recessed in the wall.

» **TECHNICAL DATA**

<b>Measuring values</b>	temperature, optional relative humidity	
<b>Output Voltage</b> <i>(type-dependent)</i>	<b>AO2V</b> 2x 0..10 V, heating & cooling, (min. load 10 kΩ)	
<b>Network technology</b>	RS485 Modbus	
<b>Power supply</b>	15..24 V = (±10%) or 24 V ~ (±10%) SELV	
<b>power consumption</b>	typ. 0,9 W (24 V =)   1 VA (24 V ~)	
<b>Measuring range temperature</b>	0..+50 °C	
<b>Measuring range humidity</b> <i>(optional)</i>	0..100% rH non-condensing	
<b>Accuracy temperature</b>	±0,5 K (typ. at 21 °C)	
<b>Accuracy humidity</b> <i>(optional)</i>	±2% between 10..90% (typ. at 21 °C)	
<b>Inputs</b> <i>(type-dependent)</i>	<b>AO2V</b> 2x inputs digital for floating contacts	<b>DI4</b> 4x inputs digital for floating contacts
<b>Protection</b>	IP30 according to EN 60529	
<b>Connection electrical</b>	terminal block, max. 1,5 mm <sup>2</sup>	
<b>Ambient condition</b>	0..+50 °C, max. 85% rH non-condensing	
<b>Mounting</b>	flush mounted in standard EU box (Ø=60 mm, min. depth=45 mm)	
<b>Notes</b>	for further variants see chapter room operating units, for other operating elements please request, for other frame designs please request	

**\*Power supply**


When several BUS devices are supplied by one 24 V AC voltage supply, it is to be ensured that all "positive" operating voltage input terminals (+) of the field devices are connected with each other and all "negative" operating voltage input terminals (-) (=reference potential) are connected together (in-phase connection of field devices).

In case of reversed polarity at one field device, a supply voltage short-circuit would be caused by that device. The consequential short-circuit current flowing through this field may cause damage to it.


Therefore, pay attention to correct wiring.

» CONNECTION PLAN


**WRF06 DI4**



**WRF06 AO2V**




» **DIP SWITCH CONFIGURATION**




LED	Description
[H1] Green	Lights up permanently during normal operation
[H2] Red	Lights up in case of a corrupt bus configuration and internal errors
[H3] Yellow	Blinks when RS485 Modbus telegrams are received and sent

**[S1] Modbus address - DIP 1..5 (binary coded)**




Dip switch	1 = on	2 = on	3 = on	4 = on	5 = on	6 = on
Value	$2^0$ (1) (factory default)	$2^1$ (2)	$2^2$ (4)	$2^3$ (8)	$2^4$ (16)	$2^5$ (32)

**[S2] Mode - DIP 1**




1	Mode
off	RTU (factory default)
on	ASCII

**[S2] Baud rate - DIP 2 and 3**




2	3	Baud
off	off	Baud 9600 (factory default)
on	off	Baud 19200
off	on	Baud 57600

**[S2] Parity – DIP 4 and 5**



4	5	Parity
off	off	None – 2-Stopbits
on	off	Even – 1 Stopbit (factory default)
off	on	Odd – 1 Stopbit

**[S2] Termination – DIP 6**



6	Termination 120 Ohm
off	Inactive (factory default)
on	Active

## » CONFIGURATION SOFTWARE AND PROTOCOL DESCRIPTION



**Modbus addresses:**  
RS485 Modbus Interface

A detailed description of the Modbus addresses can be found under the following link:  
→ [Download](#)




**Configuration software:**  
WRF06-RS485 Modbus

→ [Download](#)

---

## » DIMENSIONS (MM)

Outside dimensions are depending on the frame of the respective switch range.



---

## » ACCESSORIES (OPTIONAL)

Converter RS485 Modbus-USB incl. driver CD

PSU-UP24 – flush mount power supply 24 V (AC Input 80..240 V ~ DC Output 24 V = 0,5 A)

Item No. 668293

Item No. 668293